

To All Customers

Rep No. B16008

May 23, 2016

Fuji Electric FA  
 Components &  
 Systems Co., Ltd.

**Molded Case Circuit Breakers/Earth Leakage Circuit Breakers**

**Notification regarding Change in the Shape of the Insulation Barrier for G-TWIN 50AF, 63AF and 100AF**

We would like to thank you for your continued patronage of Fuji products.



We will be changing some products as described below. Please review the following information and take appropriate actions.

Please inform all related sections of your company.

Product name	Molded case circuit breaker/Earth leakage circuit breaker
Series and series name	G-TWIN series (50AF, 63AF and 100AF)
Type	BW50SA□, BW50RA□, BW63EA□, BW63SA□, BW63RA□, BW100EA□, EW50SA□, EW50RA□, EW63EA□, EW63SA□, EW63RA□, EW100EA□ * Derivative models of the types above are included. BZ6B10C (Main unit applicable type: BW32 to BW100, EW32 to EW100)
Changed parts	Insulation barrier
Details of the change	- Part of the insulation barrier shape is changed. - The description details are changed. For details, please see the attachment [G-TWIN Series 50AF to 100AF] Insulation Barrier Change: Old/New Appearance Comparison.
Reason for change	Improvement in production performance and environmental consideration by describing the materials used
Date of production change	Scheduled for products to be produced from September 2016
Attachment	[G-TWIN Series 50AF, 63AF and 100AF] Insulation Barrier Change: Old/New Appearance Comparison
Notes concerning the change	This change does not have any effect on the product performance or mounting dimensions.

[G-TWIN Series 50AF, 63AF and 100AF] Insulation Barrier Change: Old/New  
Appearance Comparison

---

Before change	After change
	 <p>Material mark added</p> <p>45</p> <p>8</p> <p>Thickness: 1.6 mm -&gt; 1.1 mm</p> <p>Main unit attaching section -&gt; No change</p> <p>* The type marking has been deleted</p>
<p>Target type: BZ6B10C</p>	