

To All Customers

Rep No.B24022a

March 10, 2025

Fuji Electric FA Components
& Systems Co., Ltd.

Notification of Change in Stud Material and Terminal Outer Diameter for Rear Connection Type and Flush Mounting 630AF
G-TWIN Series Molded Case Circuit Breakers and Earth Leakage Circuit Breakers

We would like to thank you for your continued patronage of Fuji products.
We will be changing some products as described below.
Please review the following information and take appropriate actions.
Please also inform all related sections of your company of these changes.

Product name	Molded case circuit breakers and earth leakage circuit breakers
Series name	G-TWIN Series 630AF
Types	BW630OAO-3, 4P, EW630OAO-3P rear connection type (X type) and flush mounting (E type) *Including derivative models and special products.
Changed parts	Stud material and outer diameter
Details of the change	The stud material will be changed from copper to aluminum. The outer diameter of the terminal will also be changed and include engraving.
Reason for change	To improve material procurability.
Date of production change	Scheduled for products to be produced from January 2026
Attachments	Attachment 1: "Details of Change of Stud Material and Outer Diameter"
Notes concerning the change	This change does not have any effect on product specifications or performance.

[Details of the change]

The stud material will be changed from copper to aluminum.

The outer diameter of the terminal will also be changed and include engraving.



There will be no change in terminal length, wiring hole position, or hole diameter.

Stud

Appearance of rear connection type

(1) Stud for 630AF

Unit: mm

Current product	Changed product
<p>Material: Copper</p> 	<p>Material: Aluminum</p> <p>Engraving 630AF Al</p> 