

### Recent Supply of Fuji S-Formers for Aluminum Reduction from 1990

Destination	No. of Units	DC kA/Unit	Total DC kA	DC V	Total DC kW	Delivery	Cooling Type of Rectifier	VCR	P'RY kV	N.B.
USA	2	32	64	600	38,400	1990	FAA	40 V	34.5	
Canada	4	105	420	1250	525,000	1991	FWA	50 V	69	
New Zealand	4	50	200	940	188,000	1993	FWA	40 V	33	
South Africa	1	60	60	100	6,000	1993	FWA	YES	33	
USA	1	20	20	890	17,800	1994	FA	No	13.2	Thyristor
New Zealand	4	66.7	266.8	500	133,400	1995	FWA	50 V	33	
New Zealand	1	50	50	940	47,000	1995	FWA	40 V	33	
Australia	5	86	430	1200	516,000	1996	FWA	40 V	<b>132</b>	
China	4	68	272	680	184,960	1996	FWA	60 V	<b>110</b>	
China	2	60	120	920	110,400	1997	FWA	No	22	Thyristor
USA	2	42	84	825	69,300	1998	FWA	50 V	34.5	
Mozambique	5	85	425	1330	565,250	1999	FWA	40 V	<b>132</b>	
China	2	60	120	920	110,400	2000	FWA	No	22	Thyristor
USA	6	30	180	1020	183,600	2001	FWA	40 V	16	
Australia	8	82.5	660	1450	957,000	2001	FWA	40 V	<b>132</b>	
Mozambique	5	85	425	1330	565,250	2002	FWA	40 V	<b>132</b>	
Canada	1	50	50	1250	62,500	2003	FWA	50 V	69	
USA	1	35	35	600	21,000	2003	FAA	40 V	34.5	
Bahrain	6	72	432	1580	682,560	Under mfg	FWA	60 V	<b>220</b>	
Iran	4	68	272	960	261,120	Under mfg	FWA	60 V	<b>132</b>	

VCR : Voltage Control Reactors (Saturable reactors)